



TRIPLE SERVICE MANIFOLD

NOT TO SCALE

NOTES:

1. USE GATE VALVE SERVICE CONNECTION. SEE DETAIL 701.
2. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD SHALL BE 6" LONG.
FOR 1" METER SETTERS, MANIFOLD SHALL BE 12" LONG.
3. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD SIZE SHALL BE 3/4" FROM BUSHING AT CROSS.
FOR 1" METER SETTERS, MANIFOLD SIZE SHALL BE 1" FROM BUSHING AT CROSS.
4. FOR 5/8" x 3/4" METER SETTERS, USE 1-17"x30" METER BOX AS SHOWN.
FOR 1" METER SETTERS, USE INDIVIDUAL METER BOXES SIMILAR TO THE SINGLE SERVICE DETAIL 703.
5. THE METER BOX SHALL BE CENTERED OVER THE SETTER ASSEMBLY AS SHOWN.

APPROVED: LYNN ARAKAKI

REV. DATE: NOV. 01, 2005

WATER/WASTEWATER DIVISION



STANDARD DETAILS

**TRIPLE SERVICE
MANIFOLD**

FILE SD703B.DGN | DRAWING NO. **703B**